

# Prüfbescheinigung *Declaration of Conformity*

**Antragsteller:**  
**Applicant:**

**Victron Energy B.V.**  
De Paal 35  
1351 JG Almere Haven  
Netherlands

**Produkttyp:**  
**Product type:**

**Battery inverter/charger**

**Modell:**  
**Model:**

**MultiGrid-II 48/3000/35-32**  
**MultiPlus-II 48/3000/35-32**

**Leistung:**  
**Rating:**

Input: 48Vdc, 75Amax (discharge), 35Amax (charge)  
Output: 230V, 1Ph + N + PE, 50Hz, 11Amax (discharge), 16Amax (charge), 2,4kW

Ein repräsentatives Prüfmuster des oben genannten Modells bestand die Prüfung nach:  
*A representative test sample of above stated model passed the tests according to:*

**Norm:**  
**Standard:**

IEC/EN 62040-1:2008 + A1:2013  
IEC/EN 62109-1:2010  
IEC/EN 62109-2:2011

**Berichtsnummer:**  
**Report no:**

17PP264-01\_0; 17PP264-02\_0; 17PP264-03\_0

**Zertifikatsnummer:**  
**Certificate no:**

18-208-00

**Ausstelldatum:**  
**Date of issue:**

2018-07-20



**Raphael Rader**

